

DRINKING WATER QUALITY - ATTOCK RURAL AREAS

Sr. No	Sample Code	Village	Union Council	Tehsil	Location	Source	Depth (ft)	Water Table Depth	EC µs/cm	pH	Turbidity NTU	Color	Taste	Odor	TDS	Alk mg/l	HCO ₃ mg/l	CO ₃ mg/l	Cl mg/l	SO ₄ mg/l	Ca mg/l	Mg mg/l	Hardness	Na mg/l	K mg/l	NO ₃ mg/l	PO ₄ mg/l	F mg/l	Fe mg/l	As ppb	Pb ppb	Total Coliforms	E.Coli	Safe/Unsafe	Permissible Limits (PSCQ)		
																																			6.5-8.5	6.5-8.5	5.0
1	Attock-01	Pathar Gash	Kot soondi	Hassan Abdal											0	5	270	0	129	252	138	96	740	61	4	13.00	0.10	0.52	0.02	0.31	5.92	+ve	+ve	Unsafe			
2	Attock-02	Pathar Gash	Kot soondi	Hassan Abdal	Sultan House	M.Pump	140	90	815	7.4	1.9	C.Less	Un.Cbly	Un.Cbly	448	6	315	0	30	50	48	42	295	59	3	2.00	0.09	0.37	0.06	0.06	6.67	+ve	+ve	Unsafe			
3	Attock-03	Pathar Gash	Kot soondi	Hassan Abdal	M. Auran House	H.Pump	150	60	882	8.0	2.5	C.Less	Un.Cbly	Un.Cbly	385	4	180	0	10	56	48	32	250	52	3	1.00	0.07	0.38	0.01	1.50	BDL	+ve	+ve	Unsafe			
4	Attock-04	Pathar Gash	Kot soondi	Hassan Abdal	Shah Mawar House	M.Pump	280	60	485	7.8	11.2	C.Less	Un.Cbly	Un.Cbly	281	4	190	0	12	62	32	10	120	55	2	0.00	0.13	0.30	0.00	1.54	0.51	+ve	+ve	Unsafe			
5	Attock-05	Pathar Gash	Kot soondi	Hassan Abdal	M.Basher House	Well	100		490	7.2	0.6	C.Less	Un.Cbly	Un.Cbly	280	4	185	0	12	62	32	9	115	53	2	2.00	0.20	0.29	0.70	0.46	0.61	+ve	+ve	Unsafe			
6	Attock-06	Kot Soondi	Kot soondi	Hassan Abdal	Ashgar Hassan House	T.Well	65	20	1433	7.9	0.8	C.Less	Un.Cbly	Un.Cbly	800	8	395	0	79	50	52	30	255	220	5	13.00	0.17	0.35	0.02	0.74	0.29	+ve	+ve	Unsafe			
7	Attock-07	Kot Soondi	Kot soondi	Hassan Abdal	M.Safiq House	Well	54	30	1277	7.8	0.3	C.Less	Un.Cbly	Un.Cbly	776	6	285	0	93	226	40	46	290	160	5	13.00	0.20	0.40	0.04	0.62	4.54	+ve	+ve	Unsafe			
8	Attock-08	Kot Soondi	Kot soondi	Hassan Abdal	Haji Fazal Hall House	H.Pump	157	40	559	8.1	1.1	C.Less	Un.Cbly	Un.Cbly	307	4	190	0	14	79	24	10	100	80	2	0.00	0.12	0.34	0.09	0.70	2.29	+ve	+ve	Unsafe			
9	Attock-09	Kot Soondi	Kot soondi	Hassan Abdal	Haji Fazal Hall House	Well	60	18	1638	7.8	0.3	C.Less	Un.Cbly	Un.Cbly	846	8	420	0	79	50	64	30	285	225	5	12.00	0.09	0.35	0.00	0.92	4.41	+ve	+ve	Unsafe			
10	Attock-10	Kot Soondi	Kot soondi	Hassan Abdal	M.Riaz Khan House	Well	60	20	1235	7.9	1.1	C.Less	Un.Cbly	Un.Cbly	704	8	405	0	64	87	40	31	290	185	5	10.00	0.13	0.22	0.02	0.65	3.40	+ve	+ve	Unsafe			
11	Attock-11	Burhan	Burhan	Hassan Abdal	Ashar Khan House	Well	65	35	540	7.5	0.3	C.Less	Un.Cbly	Un.Cbly	297	5	250	0	5	34	62	30	280	20	4	1.00	0.15	0.39	0.02	0.55	BDL	+ve	+ve	Unsafe			
12	Attock-12	Burhan	Burhan	Hassan Abdal	Pervez Khan House	Well	60	30	543	7.6	24.1	C.Less	Un.Cbly	Un.Cbly	299	5	250	0	14	35	76	12	240	20	2	2.00	0.23	0.40	0.01	0.24	BDL	+ve	+ve	Unsafe			
13	Attock-13	Burhan	Burhan	Hassan Abdal	Ghulam Sarwar House	Well	50	25	547	7.6	2.5	C.Less	Un.Cbly	Un.Cbly	301	5	250	0	6	38	64	29	280	20	2	3.00	0.10	0.40	0.01	0.37	0.44	+ve	+ve	Unsafe			
14	Attock-14	Burhan	Burhan	Hassan Abdal	M.Shafiq House	Well	78	40	618	7.7	1.5	C.Less	Un.Cbly	Un.Cbly	340	5	250	0	7	71	74	23	280	20	2	1.00	0.07	0.35	0.04	0.33	0.38	+ve	+ve	Unsafe			
15	Attock-15	Burhan	Burhan	Hassan Abdal	Asad Ali House	M.Pump	50	30	621	7.3	2.8	C.Less	Un.Cbly	Un.Cbly	354	5	255	0	12	61	68	21	255	29	2	2.00	0.14	0.36	0.07	0.63	0.38	+ve	+ve	Unsafe			
16	Attock-16	Tanda	Bhalar Jogi	Hassan Abdal	Abdul Goryam	W.Supply	300	90	594	7.4	0.9	C.Less	Un.Cbly	Un.Cbly	344	6	275	0	14	28	76	23	285	21	2	4.00	0.06	0.30	0.18	0.20	BDL	+ve	+ve	Unsafe			
17	Attock-17	Tanda	Bhalar Jogi	Hassan Abdal	M.Safiq House	W.Supply	300	90	598	7.5	0.4	C.Less	Un.Cbly	Un.Cbly	347	6	280	0	12	31	78	23	290	22	2	3.00	0.13	0.28	0.12	0.30	BDL	+ve	+ve	Unsafe			
18	Attock-18	Tanda	Bhalar Jogi	Hassan Abdal	Haji Farman	T.Well	120	80	640	7.5	0.4	C.Less	Un.Cbly	Un.Cbly	358	6	305	0	17	14	70	24	275	29	2	4.00	0.17	0.31	0.11	0.27	BDL	+ve	+ve	Unsafe			
19	Attock-19	Tanda	Bhalar Jogi	Hassan Abdal	M.Sheraz	M.Pump	130	80	625	7.5	0.3	C.Less	Un.Cbly	Un.Cbly	350	6	290	0	12	13	70	30	300	26	2	3.00	0.21	0.29	0.19	0.38	BDL	+ve	+ve	Unsafe			
20	Attock-20	Tanda	Bhalar Jogi	Hassan Abdal	Abdul Shaqoor	W.Supply	300	100	623	7.2	2.8	C.Less	Un.Cbly	Un.Cbly	343	6	275	0	14	32	78	18	270	21	1	4.00	0.13	0.30	BDL	0.15	3.44	+ve	+ve	Unsafe			
21	Attock-21	Bhedian	Bhalar Jogi	Hassan Abdal	M.Lqbal	Well	48	13	710	7.7	0.6	C.Less	Un.Cbly	Un.Cbly	405	7	370	0	6	10	60	36	300	36	3	7.00	0.09	0.44	0.32	2.92	BDL	+ve	+ve	Unsafe			
22	Attock-22	Bhedian	Bhalar Jogi	Hassan Abdal	Fakhar Zaman	Well	45	20	991	7.6	0.8	C.Less	Un.Cbly	Un.Cbly	565	8	410	0	30	15	78	47	390	53	10	12.00	0.11	0.39	0.12	1.37	2.19	+ve	+ve	Unsafe			
23	Attock-23	Bhedian	Bhalar Jogi	Hassan Abdal	M.Arshad	Well	66	22	1226	7.5	0.4	C.Less	Un.Cbly	Un.Cbly	71	10	510	0	9	32	62	47	355	67	80	10.00	0.11	0.29	BDL	1.33	1.70	+ve	+ve	Unsafe			
24	Attock-24	Bhedian	Bhalar Jogi	Hassan Abdal	M.Arshad	Well	50	25	1205	7.5	0.4	C.Less	Un.Cbly	Un.Cbly	699	10	500	0	42	52	72	74	485	70	15	10.00	0.07	0.30	0.11	1.27	BDL	+ve	+ve	Unsafe			
25	Attock-25	Bhedian	Bhalar Jogi	Hassan Abdal	Baranar Khan	M.Pump	80	20	663	7.4	1.8	C.Less	Un.Cbly	Un.Cbly	365	7	335	0	6	9	24	62	315	20	2	4.00	0.13	0.16	BDL	0.83	BDL	+ve	+ve	Unsafe			
26	Attock-26	Sultan Pur	Pind Mehri	Hassan Abdal	Abdul Razaq	W.Supply	250	30	529	7.7	4.4	C.Less	Un.Cbly	Un.Cbly	301	5	245	0	5	25	68	25	275	18	1	3.00	0.11	0.23	0.02	0.35	BDL	+ve	+ve	Unsafe			
27	Attock-27	Sultan Pur	Pind Mehri	Hassan Abdal	Khalid Mehmood	W.Supply	250	30	528	7.4	1.1	C.Less	Un.Cbly	Un.Cbly	301	5	250	0	4	20	70	24	275	18	1	4.00	0.15	0.26	0.03	0.38	BDL	+ve	+ve	Unsafe			
28	Attock-28	Sultan Pur	Pind Mehri	Hassan Abdal	Sher Zaman	W.Supply	250	30	531	7.4	1.0	C.Less	Un.Cbly	Un.Cbly	295	5	245	0	5	24	28	41	240	18	1	3.00	0.10	0.24	0.13	0.30	BDL	+ve	+ve	Unsafe			
29	Attock-29	Sultan Pur	Pind Mehri	Hassan Abdal	M.Alyas	W.Supply	250	30	529	7.4	5.4	C.Less	Un.Cbly	Un.Cbly	296	5	255	0	4	19	56	24	240	18	2	3.00	0.07	0.25	BDL	0.21	0.59	+ve	+ve	Unsafe			
30	Attock-30	Sultan Pur	Pind Mehri	Hassan Abdal	Motboob Khan	W.Supply	250	30	526	7.5	0.6	C.Less	Un.Cbly	Un.Cbly	300	5	245	0	24	23	68	25	275	18	2	2.00	0.15	0.27	0.01	0.26	BDL	+ve	+ve	Unsafe			
31	Attock-31	Bhui Gash	Pour Miana	Hassan Abdal	Haji Rehmat Din	W.Supply	320	45	539	7.7	3.4	C.Less	Un.Cbly	Un.Cbly	313	4	220	0	6	65	72	27	290	9	1	1.00	0.10	0.24	0.03	0.45	0.25	+ve	+ve	Unsafe			
32	Attock-32	Bhui Gash	Pour Miana	Hassan Abdal	Rahen ahmed	W.Supply	320	45	340	7.6	8.0	C.Less	Un.Cbly	Un.Cbly	313	5	225	0	5	65	76	23	285	10	2	2.00	0.09	0.23	0.02	0.36	4.53	+ve	+ve	Unsafe			
33	Attock-33	Bhui Gash	Pour Miana	Hassan Abdal	Mahmood	W.Supply	320	45	541	7.7	1.0	C.Less	Un.Cbly	Un.Cbly	314	5	225	0	5	63	68	24	270	11	2	2.00	0.17	0.26	0.01	0.41	0.50	+ve	+ve	Unsafe			
34	Attock-34	Bhui Gash	Pour Miana	Hassan Abdal	Saleem Khan	W.Supply	320	45	3538	7.7	1.6	C.Less	Un.Cbly	Un.Cbly	307	4	205	0	5	64	70	21	260	10	2	2.00	0.13	0.27	0.01	0.11	BDL	+ve	+ve	Unsafe			
35	Attock-35	Bhui Gash	Pour Miana	Hassan Abdal	M.Maskeen	W.Supply	320	45	537	7.6	1.3	C.Less	Un.Cbly	Un.Cbly	306	4	205	0	5	57	72	22	270	10	2	2.00	0.21	0.24	0.05	0.47	BDL	+ve	+ve	Unsafe			
36	Attock-36	Kohlia	Jallo	Hassan Abdal	Imtiyaz Ali	W.Supply	270	40	456	7.6	1.5	C.Less	Un.Cbly	Un.Cbly	251	4	195	0	10	23	36	10	130	40	2												

Sr. No	Sample Code	Village	Union Council	Tehsil	Location	Source	Depth (ft)	Water Table Depth (ft)	EC /µS/cm	pH	Turbidity NTU	Color	Taste	Odor	TDS	Alk m.mol/l	HCO ₃ mg/l	CO ₃ mg/l	Cl mg/l	SO ₄ mg/l	Ca mg/l	Mg mg/l	Hardness	Na mg/l	K mg/l	NO ₃ mg/l	PO ₄ mg/l	F mg/l	Fe mg/l	As ppb	Pb ppb	Total Coliform	E.Coli	Safe/Unsafe
81	Attock-81	Jalalia	Jalalia	Hazro	Mean Khan	Well	36	15	760	7.5	0.4	C.Less	Un.Cbly	Un.Cbly	418	5	260	0	5	74	56	33	275	41	12	7.00	0.13	0.37	0.03	2.09	BDL	+ve	-ve	Unsafe
82	Attock-82	Jalalia	Jalalia	Hazro	Nawaz Ahmed	Well	40	20	894	7.6	0.6	C.Less	Un.Cbly	Un.Cbly	495	5	240	0	40	79	80	27	310	49	23	12.00	0.07	0.32	0.04	1.99	4.00	+ve	-ve	Unsafe
83	Attock-83	Jalalia	Jalalia	Hazro	Aggarwal Ganga	Well	36	8	978	7.7	0.9	C.Less	Un.Cbly	Un.Cbly	523	5	235	0	59	64	76	29	310	59	21	10.00	0.10	0.36	0.03	1.67	2.08	+ve	-ve	Unsafe
84	Attock-84	Jalalia	Jalalia	Hazro	Ajlan Khan	Well	25	10	828	7.9	0.9	C.Less	Un.Cbly	Un.Cbly	455	5	240	0	32	47	70	30	300	38	8	10.00	0.09	0.30	0.00	0.88	2.48	+ve	-ve	Unsafe
85	Attock-85	Jalalia	Jalalia	Hazro	Naseem Akhtar	Well	26	10	768	7.4	0.7	C.Less	Un.Cbly	Un.Cbly	422	5	250	0	26	28	78	18	270	41	6	9.00	0.14	0.26	0.02	1.47	BDL	+ve	-ve	Unsafe
86	Attock-86	Malik Mala	Malik Mala	Hazro	Daira Tariq Khan	Well	60	40	953	7.3	1.6	C.Less	Un.Cbly	Un.Cbly	524	7	325	0	36	110	56	65	410	40	4	4.00	0.17	0.41	0.01	1.97	0.00	+ve	-ve	Unsafe
87	Attock-87	Malik Mala	Malik Mala	Hazro	Khalid Mehmood	Well	45	35	1159	7.4	0.6	C.Less	Un.Cbly	Un.Cbly	660	5	270	0	72	197	26	96	460	58	4	13.00	0.21	0.53	0.00	3.05	BDL	+ve	-ve	Unsafe
88	Attock-88	Malik Mala	Malik Mala	Hazro	Nawab Khan	Well	50	40	651	7.8	0.9	C.Less	Un.Cbly	Un.Cbly	309	4	195	0	18	32	44	29	230	21	3	10.00	0.20	0.40	0.00	2.75	3.05	+ve	-ve	Unsafe
89	Attock-89	Malik Mala	Malik Mala	Hazro	Malik Mala Masjid	Well	55	40	780	7.6	0.9	C.Less	Un.Cbly	Un.Cbly	429	6	285	0	13	78	56	41	310	41	3	7.00	0.13	0.59	0.01	2.01	5.03	+ve	-ve	Unsafe
90	Attock-90	Malik Mala	Malik Mala	Hazro	Ajmal kahin House	Well	50	35	982	7.6	0.4	C.Less	Un.Cbly	Un.Cbly	540	7	330	0	18	73	74	44	365	58	5	6.00	0.07	0.56	0.02	1.36	3.72	+ve	-ve	Unsafe
91	Attock-91	Yasin	Nortopa	Hazro	Dil nawaz	H.Pump	30	27	1530	7.1	1.8	C.Less	Un.Cbly	Un.Cbly	776	8	420	0	64	185	56	107	640	70	6	8.00	0.17	0.46	0.00	0.94	BDL	+ve	-ve	Unsafe
92	Attock-92	Yasin	Nortopa	Hazro	Rustam Khan	H.Pump	65	30	1060	7.1	0.4	C.Less	Un.Cbly	Un.Cbly	583	7	370	0	63	44	42	20	440	29	4	2.00	0.15	0.36	0.12	3.28	7.28	+ve	-ve	Unsafe
93	Attock-93	Yasin	Nortopa	Hazro	Abdul Haleem	Well	35	26	662	7.6	3.1	C.Less	Un.Cbly	Un.Cbly	364	6	305	0	4	33	48	39	280	31	3	2.00	0.20	0.48	0.04	1.73	5.13	+ve	-ve	Unsafe
94	Attock-94	Yasin	Nortopa	Hazro	Abdul Haleem	Well	35	29	1445	7.2	0.7	C.Less	Un.Cbly	Un.Cbly	903	9	465	0	32	290	80	70	490	120	4	1.00	0.21	0.50	0.09	0.94	2.10	+ve	-ve	Unsafe
95	Attock-95	Yasin	Nortopa	Hazro	Dilawar Khan	Well	32	26	894	7.7	0.4	C.Less	Un.Cbly	Un.Cbly	492	7	330	0	12	76	26	67	340	59	3	8.70	0.17	0.60	0.01	4.13	0.34	+ve	-ve	Unsafe
96	Attock-96	Saleem Khan	Haron	Hazro	M. Riaz	Well	40	30	1031	7.7	0.9	C.Less	Un.Cbly	Un.Cbly	556	7	360	0	36	25	40	84	495	35	3	10.00	0.23	1.11	0.01	2.36	1.97	+ve	-ve	Unsafe
97	Attock-97	Saleem Khan	Haron	Hazro	Shohib	Well	50	42	844	7.4	3.6	C.Less	Un.Cbly	Un.Cbly	464	6	310	0	24	20	44	63	370	28	3	13.00	0.27	0.68	0.11	2.13	1.92	+ve	-ve	Unsafe
98	Attock-98	Saleem Khan	Haron	Hazro	Mushtaq	Well	40	35	954	7.4	0.5	C.Less	Un.Cbly	Un.Cbly	514	7	355	0	34	18	56	66	410	28	8	10.00	0.19	0.64	0.13	2.78	3.21	+ve	-ve	Unsafe
99	Attock-99	Saleem Khan	Haron	Hazro	Masjid	Well	45	35	1207	7.6	2.2	C.Less	Un.Cbly	Un.Cbly	620	8	420	0	48	34	100	63	510	45	10	10.00	0.09	0.66	0.17	2.63	1.85	+ve	-ve	Unsafe
100	Attock-100	Saleem Khan	Haron	Hazro	M.Lahfaq House	Well	40	30	1109	7.9	1.0	C.Less	Un.Cbly	Un.Cbly	610	9	440	0	36	61	34	78	530	20	7	10.00	0.11	0.62	0.20	1.74	BDL	+ve	-ve	Unsafe
101	Attock-101	Musa Kadlathi	Bahadur Khan	Hazro	Dera Sajjad Khan	H.Pump	72	20	353	7.7	0.8	C.Less	Un.Cbly	Un.Cbly	211	3	160	0	2	5	42	17	175	9	7	0.50	0.19	0.24	0.15	5.02	BDL	+ve	-ve	Unsafe
102	Attock-102	Musa Kadlathi	Bahadur Khan	Hazro	Masjid	H.Pump	60	20	327	8.1	0.2	C.Less	Un.Cbly	Un.Cbly	207	3	150	0	4	44	18	185	9	2	0.50	0.23	0.26	0.01	5.89	2.40	+ve	-ve	Unsafe	
103	Attock-103	Musa Kadlathi	Bahadur Khan	Hazro	Ehsan Ahmad	W. Supply	35	18	320	7.7	0.9	C.Less	Un.Cbly	Un.Cbly	209	3	150	0	1	2	46	18	190	6	1	0.50	0.15	0.24	0.01	2.58	9.93	+ve	-ve	Unsafe
104	Attock-104	Musa Kadlathi	Bahadur Khan	Hazro	Master Daud	W. Supply	36	18	384	7.5	1.7	C.Less	Un.Cbly	Un.Cbly	227	3	160	0	12	2	56	15	200	7	5	0.50	0.09	0.25	0.02	5.31	0.00	+ve	-ve	Unsafe
105	Attock-105	Musa Kadlathi	Bahadur Khan	Hazro	Fiaz Shah	W. Supply	18	12	523	7.6	0.7	C.Less	Un.Cbly	Un.Cbly	282	3	150	0	54	23	68	15	230	10	2	2.00	0.10	0.25	0.04	2.10	0.00	+ve	-ve	Unsafe
106	Attock-106	Abdul	Hazro	Hazro	NRSP officax	H.Pump	35	15	2220	7.3	115.0	Mudy	Un.Cbly	Un.Cbly	990	10	500	0	50	235	68	18	245	272	15	5.00	0.07	0.33	0.29	1.56	0.00	+ve	-ve	Unsafe
107	Attock-107	Abdul	Hazro	Hazro	High School for girls	Well	30	15	673	7.6	0.7	C.Less	Un.Cbly	Un.Cbly	370	5	255	0	27	32	108	30	530	41	6	6.00	0.14	0.38	0.03	1.89	3.32	+ve	-ve	Unsafe
108	Attock-108	Abdul	Hazro	Hazro	Mumtaz pathwari	H.Pump	35	22	1034	7.3	0.3	C.Less	Un.Cbly	Un.Cbly	569	8	380	0	60	41	52	36	245	51	20	10.00	0.07	0.40	0.09	4.11	7.60	+ve	-ve	Unsafe
109	Attock-109	Abdul	Hazro	Hazro	Jameed Khan	H.Pump	30	15	32096	7.1	8.8	C.Less	Un.Cbly	Un.Cbly	1134	11	565	0	240	49	92	66	415	112	22	10.00	0.06	0.53	0.02	1.23	BDL	+ve	-ve	Unsafe
110	Attock-110	Abdul	Hazro	Hazro	Musarat Bibi	H.Pump	35	21	1316	7.1	BDL	C.Less	Un.Cbly	Un.Cbly	970	10	520	0	255	32	120	88	820	85	25	0.70	0.13	0.50	0.04	2.56	BDL	+ve	-ve	Unsafe
111	Attock-111	Kaswani	Khaswani	Hazro	Saeed Akhter	H.Pump	30	15	710	7.6	0.4	C.Less	Un.Cbly	Un.Cbly	405	6	295	0	23	17	84	26	315	24	1	13.00	0.07	0.60	0.02	2.87	2.23	+ve	-ve	Unsafe
112	Attock-112	Kaswani	Khaswani	Hazro	Hazar Khan	H.Pump	60	20	872	7.3	0.3	C.Less	Un.Cbly	Un.Cbly	480	7	365	0	54	25	96	46	380	38	1	2.00	0.17	0.68	0.11	3.04	6.64	+ve	-ve	Unsafe
113	Attock-113	Kaswani	Khaswani	Hazro	Ferdos Ahmad	H.Pump	28	12	505	7.5	0.5	C.Less	Un.Cbly	Un.Cbly	337	2	240	0	37	13	48	33	200	17	1	6.00	0.31	0.40	0.00	3.04	1.72	+ve	-ve	Unsafe
114	Attock-114	Kaswani	Khaswani	Hazro	Shaker Mehmood	H.Pump	50	40	584	7.4	0.5	C.Less	Un.Cbly	Un.Cbly	339	5	270	0	10	26	76	29	310	20	1	4.00	0.10	0.59	0.00	3.24	2.32	+ve	-ve	Unsafe
115	Attock-115	Kaswani	Khaswani	Hazro	Tofeeq Khan	H.Pump	60	18	732	7.4	1.1	C.Less	Un.Cbly	Un.Cbly	419	6	300	0	62	28	76	38	345	28	6	6.00	0.09	0.45	0.00	1.36	3.32	+ve	-ve	Unsafe
116	Attock-116	Sarwan	Khaswani	Hazro	Muhammad Ameen	H.Pump	35	15	1747	7.1	0.3	C.Less	Un.Cbly	Un.Cbly	1060	9	450	0	124	266	162	72	700	61	70	11.00	0.13	0.41	0.02	1.55	1.11	+ve	-ve	Unsafe
117	Attock-117	Sarwane	Khaswani	Hazro	Masjid	H.Pump	35	15	986	7.3	0.8	C.Less	Un.Cbly	Un.Cbly	542	6	300	0	58	58	120	41	470	29	5	13.00	0.22	0.24	0.04	0.84	BDL	+ve	-ve	Unsafe
118	Attock-118	Sarwan	Khaswani	Hazro	Ghulam Server	H.Pump	32	10	1395	7.3	0.5	C.Less	Un.Cbly	Un.Cbly	767	9	470	0	40	1														

Sr. No	Sample Code	Village	Union Council	Tehsil	Location	Source	Depth (ft)	Water Table Depth (ft)	EC µS/cm	pH	Turbidity (NTU)	Color	Taste	Odor	TDS	Alk. m.mol/l		HCO ₃ mg/l	CO ₃ mg/l	Cl mg/l	SO ₄ mg/l	Ca mg/l	Mg mg/l	Hardness mg/l	Na mg/l	K mg/l	NO ₃ mg/l	PO ₄ mg/l	F mg/l	Fe mg/l	As ppb	Pb ppb	Total Coliforms	E.Coli	Safe/Unsafe							
																Ca	Mg																									
							Permissible Limits (PSCC)		NGWS		6.5-8.5		5.0		C.Less		Un.Cbly		Un.Cbly		1000		NGWS		NGWS		250		500		NGWS		1000		1.50		0.30		50.00		50.00	
163	Attock-163	Mansar	Mansar	Hazro	Minha Jalal	T. Well	25	15	955	7.5	0.4	C.Less	Un.Cbly	Un.Cbly	544	7	355	0	57	51	60	39	310	60	29	7.00	0.15	0.46	BDL	9.19	2.79	+ve	+ve	Unsafe								
164	Attock-164	Mansar	Mansar	Hazro	Meer Afzal House	Well	120	70	1219	7.5	BDL	C.Less	Un.Cbly	Un.Cbly	695	8	420	0	64	73	66	34	305	92	60	9.00	0.23	0.60	0.02	5.32	BDL	+ve	+ve	Unsafe								
165	Attock-165	Mansar	Mansar	Hazro	Khan House	Well	120	70	1294	7.5	0.6	C.Less	Un.Cbly	Un.Cbly	789	9	445	0	84	259	88	51	275	108	21	5.00	0.18	0.61	0.05	2.75	6.61	+ve	+ve	Unsafe								
166	Attock-166	Gundal	Hazro	Hazro	Mumtaz Ali House	Well	130	80	647	7.6	1.3	C.Less	Un.Cbly	Un.Cbly	369	6	305	0	32	27	100	36	415	38	3	4.00	0.14	0.51	0.00	4.17	3.28	+ve	+ve	Unsafe								
167	Attock-167	Gundal	Hazro	Hazro	Bacha Khan House	Well	130	80	957	7.3	0.7	C.Less	Un.Cbly	Un.Cbly	536	6	285	0	67	17	68	32	300	58	36	2.00	0.13	0.50	0.02	0.76	3.04	+ve	+ve	Unsafe								
168	Attock-168	Gundal	Hazro	Hazro	Ghaffar House	Well	130	80	1940	7.5	2.3	C.Less	Un.Cbly	Un.Cbly	1125	11	565	0	168	187	88	22	310	240	70	1.00	0.17	0.51	BDL	0.38	0.02	+ve	+ve	Unsafe								
169	Attock-169	Gundal	Hazro	Hazro	Nasir House	Well	30	20	781	7.3	4.6	C.Less	Un.Cbly	Un.Cbly	447	6	290	0	52	35	66	26	250	46	17	7.00	0.06	0.46	0.02	3.94	BDL	+ve	+ve	Unsafe								
170	Attock-170	Gundal	Hazro	Hazro	Haji Tofail House	H.Pump	30	20	683	7.4	3.0	C.Less	Un.Cbly	Un.Cbly	376	5	270	0	30	13	76	10	230	46	8	5.00	0.07	0.42	0.02	3.67	0.59	+ve	+ve	Unsafe								
171	Attock-171	Tajabara	Shah Rai Sadullah	Fateh Jang	GPS Tajpura	T. Well	80	60	1696	7.2	2.4	C.Less	Un.Cbly	Un.Cbly	983	7	350	0	231	175	48	24	220	280	5	1.00	0.13	0.39	0.11	0.74	9.67	+ve	+ve	Unsafe								
172	Attock-172	Tajabara	Shah Rai Sadullah	Fateh Jang	Sajid Ahmad House	Well	70	50	3470	7.3	0.5	C.Less	Un.Cbly	Un.Cbly	1909	10	540	0	392	401	460	151	1020	330	24	13.00	0.14	1.12	0.15	0.39	3.71	+ve	+ve	Unsafe								
173	Attock-173	Tajabara	Shah Rai Sadullah	Fateh Jang	Naezer House	Well	60	40	917	8.0	0.3	C.Less	Un.Cbly	Un.Cbly	550	6	280	0	68	46	40	19	180	150	2	9.00	0.17	1.63	0.04	0.82	9.15	+ve	+ve	Unsafe								
174	Attock-174	Tajabara	Shah Rai Sadullah	Fateh Jang	Anir Khan House	H.Pump	110	95	2450	7.8	0.6	C.Less	Un.Cbly	Un.Cbly	1375	13	630	0	230	210	114	67	645	300	6	11.00	0.21	1.24	0.02	0.77	10.84	+ve	+ve	Unsafe								
175	Attock-175	Tajabara	Shah Rai Sadullah	Fateh Jang	Haji M. Anshraf House	Well	75	45	2610	7.7	BDL	C.Less	Un.Cbly	Un.Cbly	1515	13	650	0	239	197	58	142	730	209	6	12.00	0.19	1.22	0.01	0.41	BDL	+ve	+ve	Unsafe								
176	Attock-176	Sher Assad Ullah	Sher Assad Ullah	Fateh Jang	Shahzad Hassan House	Well	56	50	1320	7.4	0.2	C.Less	Un.Cbly	Un.Cbly	1866	11	535	0	385	365	90	74	530	480	2	8.00	0.19	1.60	0.09	0.54	19.54	+ve	+ve	Unsafe								
177	Attock-177	Sher Assad Ullah	Sher Assad Ullah	Fateh Jang	Hasaq Hussain House	Well	60	50	3070	8.0	0.1	C.Less	Un.Cbly	Un.Cbly	1269	11	560	0	212	253	40	22	190	390	2	10.00	0.13	3.24	BDL	1.09	0.01	+ve	+ve	Unsafe								
178	Attock-178	Sher Assad Ullah	Sher Assad Ullah	Fateh Jang	GHS Sher Assad Ullah	Well	110	100	987	7.4	1.8	C.Less	Un.Cbly	Un.Cbly	572	8	415	0	45	67	58	58	385	82	3	1.00	0.19	0.64	0.00	0.64	BDL	+ve	+ve	Unsafe								
179	Attock-179	Sher Assad Ullah	Sher Assad Ullah	Fateh Jang	Dost Muhammad House	Well	60	50	5170	6.9	16.1	C.Less	Un.Cbly	Un.Cbly	2844	9	445	0	611	497	295	115	1210	650	4	2.00	0.09	1.02	0.01	0.52	0.25	+ve	+ve	Unsafe								
180	Attock-180	Sher Assad Ullah	Sher Assad Ullah	Fateh Jang	Asad Ali House	Well	90	70	1616	8.0	0.7	C.Less	Un.Cbly	Un.Cbly	1005	15	755	0	98	260	20	135	310	2	11.00	0.11	3.20	0.01	1.94	2.47	+ve	+ve	Unsafe									
181	Attock-181	Jangal	Jangal	Fateh Jang	M. Yaqoob House	H.Pump	70	60	742	7.0	4.0	C.Less	Un.Cbly	Un.Cbly	469	7	355	0	22	31	72	41	375	50	3	11.00	0.13	0.78	0.01	1.32	1.78	+ve	+ve	Unsafe								
182	Attock-182	Jangal	Jangal	Fateh Jang	Masood House	Well	80	60	811	7.4	0.4	C.Less	Un.Cbly	Un.Cbly	454	7	360	0	24	62	18	69	330	46	2	5.00	0.09	0.87	0.01	0.42	0.55	+ve	+ve	Unsafe								
183	Attock-183	Jangal	Jangal	Fateh Jang	M. Zaman House	H.Pump	90	70	927	7.3	1.4	C.Less	Un.Cbly	Un.Cbly	510	7	365	0	33	64	28	70	360	52	63	10.00	0.15	0.91	0.02	0.37	1.58	+ve	+ve	Unsafe								
184	Attock-184	Jangal	Jangal	Fateh Jang	Malik Taj House	Well	80	60	776	7.3	0.8	C.Less	Un.Cbly	Un.Cbly	405	6	300	0	20	25	68	19	250	54	3	7.00	0.14	0.82	0.00	1.15	2.51	+ve	+ve	Unsafe								
185	Attock-185	Jangal	Jangal	Fateh Jang	Raja M. Anshraf	Well	90	70	781	7.2	0.2	C.Less	Un.Cbly	Un.Cbly	429	7	345	0	21	27	76	19	270	51	3	7.00	0.17	0.85	0.00	0.93	1.10	+ve	+ve	Unsafe								
186	Attock-186	Murat	Jangal	Fateh Jang	Raj Imtiaz House	Dam	70	60	877	7.3	0.6	C.Less	Un.Cbly	Un.Cbly	491	6	310	0	64	63	104	23	355	40	2	3.00	0.21	0.87	0.03	0.25	BDL	+ve	+ve	Unsafe								
187	Attock-187	Murat	Jangal	Fateh Jang	Mumtaz House	Well	90	60	2570	7.5	BDL	C.Less	Un.Cbly	Un.Cbly	1644	8	415	0	265	526	46	140	690	285	30	10.00	0.19	0.84	0.01	0.19	11.54	+ve	+ve	Unsafe								
188	Attock-188	Murat	Jangal	Fateh Jang	Noor Zaman House	Spring	80	70	877	7.3	11.0	C.Less	Un.Cbly	Un.Cbly	491	6	315	0	69	75	80	39	360	39	2	0.60	0.23	0.81	0.01	0.30	1.10	+ve	+ve	Unsafe								
189	Attock-189	Murat	Jangal	Fateh Jang	Gul Rehman Hohuse	Well	60	55	877	7.3	BDL	C.Less	Un.Cbly	Un.Cbly	482	6	300	0	69	81	50	57	360	39	14	1.00	0.27	0.82	0.01	0.19	8.37	+ve	+ve	Unsafe								
190	Attock-190	Murat	Jangal	Fateh Jang	Syed Wazir House	H.Pump	130	100	5870	6.9	2.6	C.Less	Un.Cbly	Un.Cbly	2683	5	270	0	605	846	330	258	2300	280	50	12.00	0.21	0.90	0.04	0.14	1.50	+ve	+ve	Unsafe								
191	Attock-191	Kinal	Jangal	Fateh Jang	Saqib House	Cistem	70	60	831	7.6	1.1	C.Less	Un.Cbly	Un.Cbly	457	6	280	0	76	57	44	41	280	64	3	2.00	0.17	0.30	0.03	0.26	1.54	+ve	+ve	Unsafe								
192	Attock-192	Kinal	Jangal	Fateh Jang	Javed House	Well	70	60	1977	7.1	0.9	C.Less	Un.Cbly	Un.Cbly	1005	10	490	0	195	103	44	155	750	90	7	10.00	0.19	0.51	0.00	0.17	5.13	+ve	+ve	Unsafe								
193	Attock-193	Kinal	Jangal	Fateh Jang	M. Saifia House	Well	90	70	1288	7.4	1.5	C.Less	Un.Cbly	Un.Cbly	708	8	385	0	107	25	120	53	520	58	2	12.00	0.16	0.42	0.01	0.53	1.71	+ve	+ve	Unsafe								
194	Attock-194	Kinal	Jangal	Fateh Jang	H. Basher Home	H.Pump	60	45	4640	6.8	8.3	C.Less	Un.Cbly	Un.Cbly	2254	13	635	0	519	341	98	345	1655	240	105	16.00	0.16	0.77	0.04	0.02	2.30	+ve	+ve	Unsafe								
195	Attock-195	Kinal	Jangal	Fateh Jang	Masjid	H.Pump	70	60	850	7.1	0.6	C.Less	Un.Cbly	Un.Cbly	531	6	290	0	72	55	44	41	390	36	2	12.00	0.01	0.80	0.00	0.39	22.28	+ve	+ve	Unsafe								
196	Attock-196	Ratwal	Jangal	Fateh Jang	Salim House	Well	70	50	1055	7.2	8.2	C.Less	Un.Cbly	Un.Cbly	591	9	430	0	46	44	44	57	345	98	1	8.00	0.15	0.65	0.04	0.30	1.54	+ve	+ve	Unsafe								
197	Attock-197	Ratwal	Jangal	Fateh Jang	Noor Zaman House	Well	80	60	1457	7.1	1.5	C.Less	Un.Cbly	Un.Cbly	801	8	420	0	101	75	104	46	450	130	2	11.00	0.14	0.54	0.01	0.43	3.47	+ve	+ve	Unsafe								
198	Attock-198	Ratwal	Jangal	Fateh Jang	Adam House	H.Pump	70	60	1965	7.3	0.2	C.Less	Un.Cbly	Un.Cbly	1053	9	470	0	207	81	160	73	700	134	2	13.00	0.07	0.65	0.00	0.41	7.51	+ve	+ve	Unsafe								
199	Attock-199	Ratwal	Jangal	Fateh Jang	Bilal House	Well	75	55	1990	7.1	0.8	C.Less	Un.Cbly	Un.Cbly	1154	10	480	0	214	79	26	57	685	136	3	10.00	0.09	0.67														

Sr. No	Sample Code	Village	Union Council	Tehsil	Location	Source	Depth (ft)	Water Table Depth (ft)	EC /µm/cm	pH	Turbidity NTU	Color	Taste	Odor	TDS	Alk		HCO ₃	CO ₃	Cl	SO ₄	Ca	Mg	Hardness	Na	K	NO ₃	PO ₄	F	Fe	As	Pb	Total Coliforms	E.Coli	Safe/Unsafe																																																																																																																																																																																																																																																															
																mg/l	mg/l																			mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l																																																																																																																																																																																																																																													
																Permissible Limits (PSCC)																																																																																																																																																																																																																																																																																		
																NGVS											6.5-8.5											5.0											C.Less											Un.Cbly											Un.Cbly											2000											NGVS											NGVS											NGVS											250											500											NGVS											500											500											200											NGVS											10.00											1.50											0.30											50.00											50.00																																											
245	Attock-245	Qutball	Qutball	Fateh Jang	Bus Stop	H. Pump	110	60	902	7.3	1.6	C.Less	Un.Cbly	Un.Cbly	530	6	315	0	75	152	56	27	250	86	1	0.11	0.13	0.41	0.31	0.42	2.91	+ve	-ve	Unsafe																																																																																																																																																																																																																																																																
246	Attock-246	Paghl	Gall Jagir	Fateh Jang	Baz Khan House	Well	34	20	2210	7.4	0.6	C.Less	Un.Cbly	Un.Cbly	1206	2	535	0	230	302	34	123	590	255	16	10.00	0.17	0.99	0.41	1.67	1.17	+ve	-ve	Unsafe																																																																																																																																																																																																																																																																
247	Attock-247	Paghl	Gall Jagir	Fateh Jang	Jabar House	Well	170	40	1703	7.5	0.8	C.Less	Un.Cbly	Un.Cbly	1096	10	485	0	148	322	54	33	270	280	2	7.00	0.09	0.60	0.04	0.17	4.83	+ve	-ve	Unsafe																																																																																																																																																																																																																																																																
248	Attock-248	Paghl	Gall Jagir	Fateh Jang	Ghulam House	Well	50	40	1598	7.8	0.8	C.Less	Un.Cbly	Un.Cbly	1072	10	485	0	128	258	60	34	290	280	3	4.00	0.14	1.57	0.04	1.93	6.49	+ve	-ve	Unsafe																																																																																																																																																																																																																																																																
249	Attock-249	Paghl	Gall Jagir	Fateh Jang	Sultan House	Well	70	25	1718	7.3	17.4	C.Less	Un.Cbly	Un.Cbly	1031	9	455	0	148	345	46	33	250	275	3	8.00	0.18	0.91	0.02	0.20	5.73	+ve	-ve	Unsafe																																																																																																																																																																																																																																																																
250	Attock-250	Paghl	Gall Jagir	Fateh Jang	Zahid House	Well	40	20	1941	7.3	4.0	C.Less	Un.Cbly	Un.Cbly	1165	9	440	0	231	321	50	50	250	250	3	8.00	0.15	0.87	0.03	0.72	1.43	+ve	-ve	Unsafe																																																																																																																																																																																																																																																																
251	Attock-251	Gall Jagir	Gall Jagir	Fateh Jang	Mukhtar Ahmed	W. Supply	220	110	1375	7.6	0.1	C.Less	Un.Cbly	Un.Cbly	825	10	510	0	44	160	106	11	310	170	3	1.00	0.09	1.00	0.01	0.27	1.29	+ve	-ve	Unsafe																																																																																																																																																																																																																																																																
252	Attock-252	Gall Jagir	Gall Jagir	Fateh Jang	Atta M. House	W. Supply	220	110	1376	7.6	BDL	C.Less	Un.Cbly	Un.Cbly	773	12	605	0	44	133	106	12	315	165	3	1.00	0.21	0.98	0.04	0.24	2.63	+ve	-ve	Unsafe																																																																																																																																																																																																																																																																
253	Attock-253	Gall Jagir	Gall Jagir	Fateh Jang	Dawood House	W. Supply	220	110	1375	7.6	BDL	C.Less	Un.Cbly	Un.Cbly	825	10	520	0	44	316	62	17	365	175	3	1.00	0.17	1.01	0.02	1.46	2.19	+ve	-ve	Unsafe																																																																																																																																																																																																																																																																
254	Attock-254	Gall Jagir	Gall Jagir	Fateh Jang	Ghulam House	W. Supply	220	110	879	7.4	1.1	C.Less	Un.Cbly	Un.Cbly	492	4	175	0	95	126	48	22	200	90	3	1.30	0.09	0.40	0.04	0.18	2.23	+ve	-ve	Unsafe																																																																																																																																																																																																																																																																
255	Attock-255	Gall Jagir	Gall Jagir	Fateh Jang	Saeed House	W. Supply	220	110	1375	7.7	BDL	C.Less	Un.Cbly	Un.Cbly	830	10	510	0	43	263	52	44	310	175	3	1.00	0.13	1.03	1.03	0.23	2.55	+ve	-ve	Unsafe																																																																																																																																																																																																																																																																
256	Attock-256	Dera Rai Ditta	Malai	Fateh Jang	Tarveer House	H. Pump	70	35	1370	7.6	BDL	C.Less	Un.Cbly	Un.Cbly	834	10	515	0	44	263	52	44	310	175	3	1.00	0.01	1.03	0.08	0.64	2.55	+ve	-ve	Unsafe																																																																																																																																																																																																																																																																
257	Attock-257	Dera Rai Ditta	Malai	Fateh Jang	Saleem House	Cistem	70	35	980	7.6	BDL	C.Less	Un.Cbly	Un.Cbly	574	9	450	0	30	43	46	29	235	120	1	1.00	0.14	1.03	0.02	0.49	BDL	+ve	-ve	Unsafe																																																																																																																																																																																																																																																																
258	Attock-258	Dera Rai Ditta	Malai	Fateh Jang	Khan Malook House	Cistem	70	35	982	7.8	BDL	C.Less	Un.Cbly	Un.Cbly	557	9	455	0	30	55	46	29	225	122	0	2.00	0.01	1.04	0.04	0.50	8.13	+ve	-ve	Unsafe																																																																																																																																																																																																																																																																
259	Attock-259	Dera Rai Ditta	Malai	Fateh Jang	M. Hafeez House	H. Pump	70	35	2170	7.2	BDL	C.Less	Un.Cbly	Un.Cbly	1194	8	385	0	230	235	112	73	580	200	19	13.00	0.17	0.67	0.09	0.38	2.22	+ve	-ve	Unsafe																																																																																																																																																																																																																																																																
260	Attock-260	Dera Rai Ditta	Malai	Fateh Jang	Muhrav Khan	Cistem	70	35	997	7.6	BDL	C.Less	Un.Cbly	Un.Cbly	578	9	450	0	31	21	54	25	230	120	1	1.00	0.15	1.01	0.05	0.39	BDL	+ve	-ve	Unsafe																																																																																																																																																																																																																																																																
261	Attock-261	Malai	Malai	Fateh Jang	Maula dad	Well	110	70	1546	8.2	0.2	C.Less	Un.Cbly	Un.Cbly	928	10	510	0	81	210	26	23	135	285	1	1.50	0.13	1.83	0.05	1.03	1.25	+ve	-ve	Unsafe																																																																																																																																																																																																																																																																
262	Attock-262	Malai	Malai	Fateh Jang	Maula dad	H. Pump	80	60	5380	7.2	0.2	C.Less	Un.Cbly	Un.Cbly	3228	15	740	0	194	1074	144	248	1380	590	7	13.00	0.07	0.85	BDL	2.05	15.01	+ve	-ve	Unsafe																																																																																																																																																																																																																																																																
263	Attock-263	Malai	Malai	Fateh Jang	M. Nazir House	H. Pump	50	20	2230	8.2	0.2	C.Less	Un.Cbly	Un.Cbly	1248	11	575	0	199	621	38	33	180	370	1	10.00	0.21	3.20	0.01	0.62	0.15	+ve	-ve	Unsafe																																																																																																																																																																																																																																																																
264	Attock-264	Malai	Malai	Fateh Jang	Tariq House	Cistem	110	60	727	7.3	4.1	C.Less	Un.Cbly	Un.Cbly	421	3	160	0	86	166	38	206	150	78	3	1.00	0.13	0.30	0.09	1.31	10.59	+ve	-ve	Unsafe																																																																																																																																																																																																																																																																
265	Attock-265	Malai	Malai	Fateh Jang	Allah Dad House	H. Pump	110	60	8760	7.1	7.0	C.Less	Un.Cbly	Un.Cbly	5256	10	465	0	1499	1564	280	328	2050	1100	7	12.00	0.14	1.00	1.60	0.26	2.56	+ve	-ve	Unsafe																																																																																																																																																																																																																																																																
266	Attock-266	Dermal	Dermal	Fateh Jang	Tariq House	H. Pump	145	60	1469	7.8	0.0	C.Less	Un.Cbly	Un.Cbly	852	8	505	0	56	185	24	15	120	255	30	13.00	0.09	2.42	0.30	0.40	15.92	+ve	-ve	Unsafe																																																																																																																																																																																																																																																																
267	Attock-267	Dermal	Dermal	Fateh Jang	M. Zahir House	Well	110	60	1313	7.5	0.2	C.Less	Un.Cbly	Un.Cbly	791	9	445	0	42	820	28	27	180	190	25	10.00	0.17	2.35	0.30	0.18	10.15	+ve	-ve	Unsafe																																																																																																																																																																																																																																																																
268	Attock-268	Dermal	Dermal	Fateh Jang	Khadin House	H. Pump	150	70	1694	7.5	11.5	C.Less	Un.Cbly	Un.Cbly	1000	9	445	0	98	822	44	28	725	275	164	14.00	0.09	1.77	0.04	0.26	2.24	+ve	-ve	Unsafe																																																																																																																																																																																																																																																																
269	Attock-269	Dermal	Dermal	Fateh Jang	M. Biaz House	H. Pump	140	70	1799	7.5	BDL	C.Less	Un.Cbly	Un.Cbly	1073	9	465	0	102	319	46	24	215	280	14	15.00	0.13	1.67	0.04	0.22	8.02	+ve	-ve	Unsafe																																																																																																																																																																																																																																																																
270	Attock-270	Dermal	Dermal	Fateh Jang	Masjid	H. Pump	120	65	2290	7.9	2.7	C.Less	Un.Cbly	Un.Cbly	1794	9	430	0	328	707	26	47	160	500	10	11.00	0.11	1.05	0.04	0.23	BDL	+ve	-ve	Unsafe																																																																																																																																																																																																																																																																
271	Attock-271	Kamrial	Pindi Gap	Shaukat Ali	Well	50	30	880	7.2	2.6	C.Less	Un.Cbly	Un.Cbly	484	4	175	0	30	72	48	41	290	16	1	1.00	0.23	0.42	0.05	1.49	9.92	+ve	-ve	Unsafe																																																																																																																																																																																																																																																																	
272	Attock-272	Kamrial	Pindi Gap	Amir Hussain	Well	65	30	890	7.3	BDL	C.Less	Un.Cbly	Un.Cbly	490	6	320	0	30	72	70	30	300	16	1	0.80	0.21	0.40	0.02	2.39	0.87	+ve	-ve	Unsafe																																																																																																																																																																																																																																																																	
273	Attock-273	Kamrial	Pindi Gap	Mushtaq Ahmed Home	Well	50	40	893	7.4	BDL	C.Less	Un.Cbly	Un.Cbly	491	6	300	0	31	73	65	26	270	17	1	3.00	0.18	0.41	0.07	1.00	0.95	+ve	-ve	Unsafe																																																																																																																																																																																																																																																																	
274	Attock-274	Kamrial	Pindi Gap	M Saqian Home	Well	50	35	915	7.2	BDL	C.Less	Un.Cbly	Un.Cbly	503	6	315	0	32	80	78	24	295	15	1	0.90	0.09	0.40	0.03	2.49	1.25	+ve	-ve	Unsafe																																																																																																																																																																																																																																																																	
275	Attock-275	Kamrial	Pindi Gap	Mudasser Hussain	Well	60	45	928	7.3	BDL	C.Less	Un.Cbly	Un.Cbly	510	6	320	0	34	82	80	24	300	14	1	3.00	0.14	0.39	0.01	0.12	1.42	+ve	-ve	Unsafe																																																																																																																																																																																																																																																																	
276	Attock-276	Gullal	Kamrial	Pindi Gap	Shahid Home	Well	95	70	2480	7.0	BDL	C.Less	Un.Cbly	Un.Cbly	1488	9	440	0	330	402	60	51	310	390	2	2.00	0.13	1.20	0.04	0.86	2.20	+ve	-ve	Unsafe																																																																																																																																																																																																																																																																
277	Attock-277	Gullal	Kamrial	Pindi Gap	Qadeer Ahmed Home	Well	100	80	1940	7.3	0.0	C.Less	Un.Cbly	Un.Cbly	1488	9	440	0	330	405	60	51	310	395	3	2.00	0.09	1.19	0.08	0.84	1.55	+ve	-ve	Unsafe																																																																																																																																																																																																																																																																
278	Attock-278	Gullal	Kamrial	Pindi Gap	Sabri Hussain Home	W. Supply	120	80	1938	7.5	8.9	C.Less	Un.Cbly	Un.Cbly	1043	6	300	0	362	105	48	56	350	255	3	2.00	0.17	0.42	0.07	1.39	17.07	+ve	-ve	Unsafe																																																																																																																																																																																																																																																																
279	Attock-279	Gullal	Kamrial	Pindi Gap	Shaukat Ali House	W. Supply	170	80	1938	7.5	0.4	C.Less	Un.Cbly	Un.Cbly	1038	6	285	0	360	97	76	58	390	240	2	1.00	0.20	0.40	0.09	0.11	17.65	+ve	-ve	Unsafe																																																																																																																																																																																																																																																																
280	Attock-280	Gullal	Kamrial	Pindi Gap	Nadeem Ahmed Home	H. Pump	120	80	2160	7.4	3.2	C.Less	Un.Cbly	Un.Cbly	1116	9	435	0	245	147	76	32	320	305	2	4.00	0.19	0.73	0.01	1.51	12.75	+ve	-ve	Unsafe																																																																																																																																																																																																																																																																
281	Attock-281	Kamrial	Kamrial	Pindi Gap	Gulam Muhammad House	W. Supply	120	80	668	7.3	0.9	C.Less	Un.Cbly	Un.Cbly	367	4	200	0	59	36	28	18	145	94	5	1.00	0.23	0.29	0.06	2.29	4.41	+ve	-ve	Unsafe																																																																																																																																																																																																																																																																
282	Attock-282	Kamrial	Kamrial	Pindi Gap	Fateh Khan	W. Supply	120	80	3410	8.6	1.9	C.Less	Un.Cbly	Un.Cbly	1814	12	600	0	320	479	40	51	310	530	4	13.00	0.25	2.66	0.01	3.64	14.41	+ve	-ve	Unsafe																																																																																																																																																																																																																																																																
283	Attock-283	Kamrial	Kamrial	Pindi Gap	Abid Khan	W. Supply	120	80	663	7.5	1.8	C.Less	Un.Cbly	Un.Cbly	365	4	185	0	56	66	28	12	120	95	5	1.60	0.17	0.30	0.09	1.89	1.86	+ve	-ve	Unsafe																																																																																																																																																																																																																																																																
284	Attock-284	Kamrial	Kamrial	Pindi Gap	Amanat Khan	W. Supply	120	80	657	7.2	0.9	C.Less	Un.Cbly	Un.Cbly	361	4	175	0	60	72	26	11	110	96	5	1.40	0.06	0.28	0.09	1.58	2.15	+ve	-ve	Unsafe																																																																																																																																																																																																																																																																
285	Attock-285	Kamrial	Kamrial	Pindi Gap	Sultan Khan	W. Supply	120	80	666	7.3	0.2	C.Less	Un.Cbly	Un.Cbly	322	4	185	0																																																																																																																																																																																																																																																																																

Sr. No	Sample Code	Village	Union Council	Tehsil	Location	Source	Depth (ft)	Water Table Depth (ft)	EC uS/cm	pH	Turbidity NTU	Color	Taste	Odor	TDS	Alk		HCO ₃ ⁻ mg/l	CO ₃ ⁻² mg/l	Cl mg/l	SO ₄ ⁻² mg/l	Ca mg/l	Mg mg/l	Hardness mg/l	Na mg/l	K mg/l	NO ₃ ⁻ mg/l	PO ₄ ⁻³ mg/l	F mg/l	Fe mg/l	As ppb	Pb ppb	Total Coliforms	E.Coli	Safe/Unsafe													
																mg/l	mg/l																															
							Permissible Limits (PSCC)		NGS		6.5-8.5		5.0		C.Less		Un.Cbly		Un.Cbly		2000		NGS		NGS		250		500		NGS		500		200		NGS		10.00		1.50		0.30		50.00		50.00	
327	Attock-327	Malhu Wali	Malhu Wali	Pindi Gap	Shahid Abbas	W. Supply	200	80	599	7.8	6.4	C.Less	Un.Cbly	Un.Cbly	318	5	240	0	22	34	48	260	260	16	3	7.00	0.14	0.05	0.03	0.12	2.72	+ve	-ve	Unsafe														
328	Attock-328	Malhu Wali	Malhu Wali	Pindi Gap	Shahad Abbas	W. Supply	200	80	589	8.0	1.5	C.Less	Un.Cbly	Un.Cbly	318	5	230	0	24	43	50	250	250	17	31	5.00	0.07	0.08	0.00	1.38	BDL	+ve	-ve	Unsafe														
329	Attock-329	Malhu Wali	Malhu Wali	Pindi Gap	Jahar Hussain House	H. Pump	80	30	843.0	7.5	4.9	C.Less	Un.Cbly	Un.Cbly	328	5	240	0	328	4561	270	53	890	1330	14	8.00	0.14	0.57	0.03	1.59	8.63	+ve	-ve	Unsafe														
330	Attock-330	Malhu Wali	Malhu Wali	Pindi Gap	Masjid	H. Pump	70	45	4190	7.4	2.9	C.Less	Un.Cbly	Un.Cbly	2784	9	440	0	351	2178	102	225	1180	530	7	6.00	0.13	1.59	0.11	0.55	4.32	+ve	-ve	Unsafe														
331	Attock-331	Nowshera	Chakki	Pindi Gap	Asif Javed	H. Pump	50	30	968	7.3	BDL	C.Less	Un.Cbly	Un.Cbly	610	6	290	0	49	164	58	47	360	106	3	0.30	0.07	0.55	0.02	2.00	1.54	+ve	+ve	Unsafe														
332	Attock-332	Nowshera	Chakki	Pindi Gap	M. Ramzan	H. Pump	45	30	792	7.5	1.3	C.Less	Un.Cbly	Un.Cbly	436	5	260	0	54	63	36	35	235	78	3	0.40	0.10	0.58	0.01	1.30	1.82	+ve	-ve	Unsafe														
333	Attock-333	Nowshera	Chakki	Pindi Gap	Abdul Jabbar	H. Pump	55	25	1332	7.4	1.6	C.Less	Un.Cbly	Un.Cbly	799	6	295	0	119	334	60	55	375	160	3	0.20	0.13	0.56	0.02	1.02	6.95	+ve	-ve	Unsafe														
334	Attock-334	Nowshera	Chakki	Pindi Gap	M. Farooq	H. Pump	45	20	1344	7.4	1.3	C.Less	Un.Cbly	Un.Cbly	806	7	330	0	144	262	76	43	335	158	3	0.20	0.06	0.57	0.04	1.4	4.62	+ve	-ve	Unsafe														
335	Attock-335	Nowshera	Chakki	Pindi Gap	Masjid	H. Pump	50	25	838	7.3	0.7	C.Less	Un.Cbly	Un.Cbly	461	5	265	0	47	60	38	24	195	98	2	0.30	0.14	0.46	0.05	0.74	1.22	+ve	-ve	Unsafe														
336	Attock-336	Toot	Maira Sharif	Pindi Gap	Umer Jayat	H. Pump	90	50	1502	7.2	14.3	C.Less	Un.Cbly	Un.Cbly	901	7	350	0	118	144	94	61	485	142	2	0.40	0.17	0.42	0.14	0.44	5.66	+ve	-ve	Unsafe														
337	Attock-337	Toot	Maira Sharif	Pindi Gap	M. Iqbal	H. Pump	220	110	985	8.0	0.9	C.Less	Un.Cbly	Un.Cbly	591	8	420	0	26	73	4	19	90	200	2	0.00	0.13	0.65	0.11	0.60	5.26	+ve	-ve	Unsafe														
338	Attock-338	Toot	Maira Sharif	Pindi Gap	M. Iqbal	H. Pump	90	70	921	7.8	0.6	C.Less	Un.Cbly	Un.Cbly	550	4	200	0	24	60	40	24	200	200	2	0.00	0.01	0.12	0.06	0.38	4.48	+ve	-ve	Unsafe														
339	Attock-339	Toot	Maira Sharif	Pindi Gap	Atza Muhammed	H. Pump	101	75	914	7.4	2.6	C.Less	Un.Cbly	Un.Cbly	536	5	300	0	52	109	34	26	190	130	2	2.00	0.09	0.63	0.01	0.47	2.56	+ve	-ve	Unsafe														
340	Attock-340	Toot	Maira Sharif	Pindi Gap	Masjid	H. Pump	100	75	1902	7.3	BDL	C.Less	Un.Cbly	Un.Cbly	1189	5	245	0	191	418	116	96	685	138	3	13.00	0.14	0.56	0.08	0.21	8.18	+ve	-ve	Unsafe														
341	Attock-341	Nakkah Kalah	Maira Sharif	Pindi Gap	Malik Sher Baz	H. Pump	110	50	9030	7.1	12.5	C.Less	Un.Cbly	Un.Cbly	1836	8	420	0	313	698	128	104	750	380	7	7.00	0.13	0.47	0.31	0.53	3.92	+ve	-ve	Unsafe														
342	Attock-342	Nakkah Kalah	Maira Sharif	Pindi Gap	M. Rehan	T.well	200	50	1167	7.7	0.3	C.Less	Un.Cbly	Un.Cbly	700	6	300	0	95	185	20	10	90	230	2	3.20	0.21	0.58	0.05	0.41	4.15	+ve	-ve	Unsafe														
343	Attock-343	Nakkah Kalah	Maira Sharif	Pindi Gap	M.nawaz house	H.Pump	85	40	1462	7.8	14.9	C.Less	Un.Cbly	Un.Cbly	895	4	195	0	164	272	28	9	105	280	2	13.00	0.19	0.56	0.06	0.99	1.32	+ve	-ve	Unsafe														
344	Attock-344	Nakkah Kalah	Maira Sharif	Pindi Gap	Habib Rehan	H.Pump	100	55	1176	8.3	1.6	C.Less	Un.Cbly	Un.Cbly	713	4	205	0	117	259	16	5	60	235	2	10.00	0.09	0.54	0.02	1.41	10.88	+ve	-ve	Unsafe														
7	Attock-345	Nakkah Kalah	Maira Sharif	Pindi Gap	Ghulam Hassan	H.Pump	90	45	3790	7.3	3.6	C.Less	Un.Cbly	Un.Cbly	2154	7	365	0	717	360	84	63	470	610	5	12.00	0.07	0.55	0.03	0.19	17.98	+ve	-ve	Unsafe														
346	Attock-346	Kasran	Mian Wala	Pindi Gap	Akbar Khan House	W.Supply	70	70	1101	7.7	0.6	C.Less	Un.Cbly	Un.Cbly	609	8	420	0	717	103	76	41	360	98	4	8.00	0.14	0.27	0.00	1.02	BDL	+ve	-ve	Unsafe														
347	Attock-347	Kasran	Mian Wala	Pindi Gap	Ghulam Fareed	Well	60	20	1340	7.3	0.2	C.Less	Un.Cbly	Un.Cbly	804	5	250	0	145	200	104	61	510	90	3	12.00	0.13	0.60	0.01	2.01	BDL	+ve	+ve	Unsafe														
348	Attock-348	Kasran	Mian Wala	Pindi Gap	Haji Khabib Akhter	H. Pump	70	40	2280	7.6	BDL	C.Less	Un.Cbly	Un.Cbly	1272	9	460	0	310	197	64	47	355	355	3	7.00	0.21	0.98	0.01	BDL	9.18	+ve	-ve	Unsafe														
349	Attock-349	Kasran	Mian Wala	Pindi Gap	Shafiq Ali	H. Pump	40	30	5570	7.1	15.4	C.Less	Un.Cbly	Un.Cbly	3126	14	710	0	894	498	156	136	950	600	4	4.00	0.11	0.91	0.00	0.14	19.02	+ve	-ve	Unsafe														
350	Attock-350	Kasran	Mian Wala	Pindi Gap	Asghar Ali Ali House	H.Pump	65	35	1054	7.4	1.3	C.Less	Un.Cbly	Un.Cbly	668	6	270	0	106	354	72	16	245	600	4	1.20	0.14	0.35	0.02	1.07	2.63	+ve	-ve	Unsafe														
351	Attock-351	Methal	Basal	Pindi Gap	Dilawar Masood	Cistern	160	80	896	7.7	BDL	C.Less	Un.Cbly	Un.Cbly	538	5	235	0	85	188	58	11	170	122	4	2.00	0.10	0.37	0.01	0.70	4.20	+ve	-ve	Unsafe														
352	Attock-352	Methal	Basal	Pindi Gap	M.Shakeel House	W.Supply	160	80	885	7.5	BDL	C.Less	Un.Cbly	Un.Cbly	531	5	230	0	80	110	56	9	175	108	4	0.40	0.07	0.39	0.21	0.42	5.12	+ve	-ve	Unsafe														
353	Attock-353	Methal	Basal	Pindi Gap	Ilyas House	W.Supply	160	80	882	7.6	0.1	C.Less	Un.Cbly	Un.Cbly	529	5	235	0	82	128	56	10	165	108	4	1.00	0.14	0.38	0.31	BDL	4.97	+ve	-ve	Unsafe														
354	Attock-354	Methal	Basal	Pindi Gap	Malik Ayub House	W.Supply	160	80	884	7.6	0.4	C.Less	Un.Cbly	Un.Cbly	530	4	220	0	86	125	56	10	190	108	4	0.40	0.05	0.37	0.00	0.45	2.87	+ve	-ve	Unsafe														
355	Attock-355	Methal	Basal	Pindi Gap	M.Uzman House	W.Supply	160	80	882	7.6	BDL	C.Less	Un.Cbly	Un.Cbly	589	5	230	0	106	132	58	34	285	106	4	0.03	0.08	0.36	0.03	0.72	0.87	+ve	+ve	Unsafe														
356	Attock-356	Basal	Basal	Pindi Gap	Yar Muhammad	H. Pump	90	70	936	7.2	9.5	C.Less	Un.Cbly	Un.Cbly	592	5	260	0	49	163	60	43	325	78	5	12.00	0.13	0.41	0.14	0.78	0.80	+ve	-ve	Unsafe														
357	Attock-357	Basal	Basal	Pindi Gap	Sher Khan	H. Pump	90	70	1030	7.2	0.4	C.Less	Un.Cbly	Un.Cbly	558	4	180	0	78	205	84	40	375	42	5	14.00	0.09	0.42	0.02	1.11	0.92	+ve	-ve	Unsafe														
358	Attock-358	Basal	Basal	Pindi Gap	Abdul Khalid	H. Pump	70	50	841	7.7	BDL	C.Less	Un.Cbly	Un.Cbly	505	5	230	0	67	62	32	295	55	12	12.00	0.19	0.34	0.03	1.10	1.50	+ve	+ve	Unsafe															
359	Attock-359	Basal	Basal	Pindi Gap	M. Siddique	H. Pump	80	50	850	7.4	BDL	C.Less	Un.Cbly	Un.Cbly	522	20	995	0	1240	268	820	350	3760	1320	19	14.00	0.07	0.85	0.07	BDL	5.00	+ve	-ve	Unsafe														
360	Attock-360	Basal	Basal	Pindi Gap	Masjid	H. Pump	105	75	1375	7.3	0.0	C.Less	Un.Cbly	Un.Cbly	825	6	290	0	137	147	140	36	500	90	6	14.00	0.10	0.51	0.31	0.56	BDL	+ve	-ve	Unsafe														
361	Attock-361	Nara	Nara	Jand	Malik Sher Khan House	H.Pump	70	40	462	7.3	1.2	C.Less	Un.Cbly	Un.Cbly	254	4	200	0	6	14	38	11	140	43	2	6.00	0.17	0.87	0.21	0.23	BDL	+ve	-ve	Unsafe														
362	Attock-362	Nara	Nara	Jand	Master Sadiq	H.Pump	50	35	374	7.4	0.6	C.Less	Un.Cbly	Un.Cbly	222	3	160	0	1	24	40	9	135	32	2	7.80	0.09	1.14	0.04	1.99	1.87	+ve	+ve	Unsafe														
363	Attock-363	Nara	Nara	Jand	M. Nawaz	H.Pump	55	35	352	7.4	0.6	C.Less	Un.Cbly	Un.Cbly	194	3	140	0	2	10	40	12	150	12	1	8.00	0.14	0.70																				

Sr. No	Sample Code	Village	Union Council	Tehsil	Location	Source	Depth (ft)	Water Table Depth (ft)	EC uS/cm	pH	Turbidity NTU	Color	Taste	Odor	TDS	Alk m.mol/l	HCO ₃ mg/l	CO ₃ mg/l	Cl mg/l	SO ₄ mg/l	Ca mg/l	Mg mg/l	Hardness	Na mg/l	K mg/l	NO ₃ mg/l	PO ₄ mg/l	F mg/l	Fe mg/l	As ppb	Pb ppb	Total Coliforms	E.Coli	Safe/ Unsafe
409	Attock-409	Kot Chhaji	Saghi	Jand	Mirzaman	H. Pump	60	40	1166	7.3	6.4	C.Less	Un.Obj	Un.Obj	844	7	340	0	68	279	58	38	270	148	2	5.00	0.17	1.07	0.03	0.37	5.11	+ve	-ve	Unsafe
410	Attock-410	Kot Chhaji	Saghi	Jand	Akmal Khan	Cistern	150	70	1178	7.6	0.8	C.Less	Un.Obj	Un.Obj	450	7	330	0	27	17	52	19	210	94	6	8.00	0.24	0.36	BDL	BDL	0.53	+ve	-ve	Unsafe
411	Attock-411	Aurang Abad	Pind Sultani	Jand	M. Sultan House	H. Pump	108	60	858	7.1	BDL	C.Less	Un.Obj	Un.Obj	472	7	335	0	22	68	98	27	355	42	2	3.00	0.23	0.33	BDL	BDL	0.47	+ve	-ve	Unsafe
412	Attock-412	Aurang Abad	Pind Sultani	Jand	M. Maskeen House	H. Pump	110	65	820	7.2	33.9	C.Less	Un.Obj	Un.Obj	451	7	360	0	17	55	88	26	325	40	2	0.10	0.10	0.32	2.21	BDL	BDL	+ve	-ve	Unsafe
413	Attock-413	Aurang Abad	Pind Sultani	Jand	Khalid Hussain House	H. Pump	100	70	818	7.3	0.5	C.Less	Un.Obj	Un.Obj	450	7	350	0	16	60	80	29	320	40	2	0.10	0.17	0.31	0.03	0.22	BDL	+ve	-ve	Unsafe
414	Attock-414	Aurang Abad	Pind Sultani	Jand	Saqib House	H. Pump	105	60	857	7.1	41.3	C.Less	Un.Obj	Un.Obj	471	7	355	0	22	65	76	34	375	40	2	0.20	0.16	0.32	0.52	0.36	0.02	+ve	-ve	Unsafe
415	Attock-415	Aurang Abad	Pind Sultani	Jand	Shakir Ali Hoyuse	H. Pump	90	55	1093	7.3	BDL	C.Less	Un.Obj	Un.Obj	550	5	250	0	66	150	70	26	280	40	3	5.00	0.01	0.37	0.13	BDL	2.12	+ve	-ve	Unsafe
416	Attock-416	Mirwal	Khunda	Jand	Ghulam Sanwar Khan Hour	H. Pump	30	80	1135	7.5	BDL	C.Less	Un.Obj	Un.Obj	825	5	255	0	130	200	50	18	200	56	3	13.00	0.02	0.38	0.16	BDL	2.96	+ve	-ve	Unsafe
417	Attock-417	Mirwal	Khunda	Jand	Tanweer Ahmad House	H. Pump	20	40	720	7.2	3.2	C.Less	Un.Obj	Un.Obj	396	6	310	0	17	27	62	39	315	21	1	10.00	0.17	0.99	0.11	0.20	BDL	+ve	-ve	Safe
418	Attock-418	Mirwal	Khunda	Jand	M. Usman House	H. Pump	35	75	772	7.4	BDL	C.Less	Un.Obj	Un.Obj	425	4	215	0	63	60	48	12	170	90	2	7.00	0.20	63.00	0.12	0.94	1.54	+ve	-ve	Unsafe
419	Attock-419	Mirwal	Khunda	Jand	Mehmood House	H. Pump	35	80	1835	7.7	8.4	C.Less	Un.Obj	Un.Obj	1101	8	410	0	164	215	64	44	240	270	2	14.00	0.13	0.80	0.01	BDL	3.42	+ve	-ve	Unsafe
420	Attock-420	Mirwal	Khunda	Jand	Abdul ghafar Khan House	H. Pump	35	90	1368	7.6	0.6	C.Less	Un.Obj	Un.Obj	821	6	315	0	80	203	32	27	190	224	2	12.00	0.14	0.86	0.00	0.40	3.48	+ve	-ve	Unsafe
421	Attock-421	Kahal	Khunda	Jand	Nazir Khan House	H. Pump	50	90	1184	7.5	5.0	C.Less	Un.Obj	Un.Obj	651	7	335	0	97	102	56	22	230	160	2	1.00	0.09	0.75	0.02	BDL	5.27	+ve	-ve	Safe
422	Attock-422	Kahal	Khunda	Jand	Noor Khan House	H. Pump	45	90	1398	7.8	0.1	C.Less	Un.Obj	Un.Obj	769	8	400	0	140	129	64	62	415	132	4	1.00	0.13	0.37	BDL	2.40	5.09	+ve	-ve	Safe
423	Attock-423	Kahal	Khunda	Jand	Sanwar Khan House	H. Pump	40	60	994	7.6	BDL	C.Less	Un.Obj	Un.Obj	547	7	365	0	64	45	46	62	370	66	2	6.00	0.17	0.42	0.31	1.06	1.17	+ve	-ve	Unsafe
424	Attock-424	Kahal	Khunda	Jand	M. Basheer Home	H. Pump	80		1080	7.8	1.8	C.Less	Un.Obj	Un.Obj	610	7	345	0	87	79	70	33	310	118	7	2.00	0.21	0.48	0.04	1.32	4.19	+ve	-ve	Unsafe
425	Attock-425	Kahal	Khunda	Jand	M. Ajmal Khan House	H. Pump	30	60	1772	8.0	6.0	C.Less	Un.Obj	Un.Obj	1063	12	610	0	6	270	20	34	190	335	4	0.10	0.11	1.10	0.01	1.73	12.98	+ve	-ve	Unsafe
426	Attock-426	Khunda	Khunda	Jand	M. Saddique	H. Pump	20	30	1138	7.3	1.8	C.Less	Un.Obj	Un.Obj	626	6	295	0	145	90	96	38	395	80	5	0.40	0.13	0.26	0.04	1.24	2.67	+ve	-ve	Unsafe
427	Attock-427	Khunda	Khunda	Jand	Lal Khan House	Well	20	30	1016	7.2	0.2	C.Less	Un.Obj	Un.Obj	559	5	250	0	154	40	86	29	335	78	2	3.00	0.07	0.28	BDL	0.76	2.20	+ve	-ve	Unsafe
428	Attock-428	Khunda	Khunda	Jand	Abdullah House	Well	25	35	1123	7.3	0.2	C.Less	Un.Obj	Un.Obj	618	6	305	0	150	65	114	27	395	78	2	1.00	0.05	0.30	0.32	0.14	3.29	+ve	-ve	Unsafe
429	Attock-429	Khunda	Khunda	Jand	Nazir Hussain	Well	30	70	1113	7.4	0.4	C.Less	Un.Obj	Un.Obj	612	6	280	0	157	57	104	28	375	80	2	1.00	0.13	0.32	0.14	0.10	1.12	+ve	-ve	Unsafe
430	Attock-430	Khunda	Khunda	Jand	M. Basfir House	Well	20	40	1118	7.4	BDL	C.Less	Un.Obj	Un.Obj	615	6	290	0	155	50	102	34	395	80	2	1.00	0.10	0.31	0.00	0.15	3.28	+ve	-ve	Unsafe
431	Attock-431	Pind Sultani	Pind Sultani	Jand	Haji Ball House	H. Pump	108	60	858	7.1	3.2	C.Less	Un.Obj	Un.Obj	369	6	395	0	288	265	125	57	550	238	2	0.30	0.09	1.10	0.02	0.01	7.06	+ve	-ve	Unsafe
432	Attock-432	Pind Sultani	Pind Sultani	Jand	Naveed hassan House	H. Pump	110	65	820	6.9	11.1	C.Less	Un.Obj	Un.Obj	3622	8	380	0	514	887	336	140	1415	300	47	0.60	0.17	1.03	0.09	0.02	10.34	+ve	-ve	Unsafe
433	Attock-433	Pind Sultani	Pind Sultani	Jand	Sardaraz Khan House	H. Pump	100	70	818	7.8	0.6	C.Less	Un.Obj	Un.Obj	764	5	255	0	194	118	48	40	285	152	3	0.10	0.17	0.48	0.02	0.06	9.75	+ve	-ve	Unsafe
434	Attock-434	Pind Sultani	Pind Sultani	Jand	Allah Dad House	H. Pump	105	60	857	8.0	1.2	C.Less	Un.Obj	Un.Obj	810	5	255	0	194	155	46	47	310	150	3	0.40	0.13	0.47	BDL	0.09	5.83	+ve	-ve	Unsafe

%age of Sample beyond permissible limit		0.23	12.90	19.12	11.29	6.45	17.51	19.35	4.38	4.84	0.00	0.00	84.56	21.20	89.17														
No. of Samples beyond permissible limit out of 434		1	56	83	49	28	76	84	19	21	0	0	367	92	387														
Min.	15	8	301	6.8	0.1	0	2	125	0	1	2	4	5	43	6	0	0.00	0.01	0.05	0.00	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Average	98	53	1493	7.5	5.2	841	6	323	0	125	190	74	50	368	142	8	5.80	0.17	0.74	0.07	1.30	4.09							
Max.	360	280	32096	8.6	603.0	22706	20	995	0	2480	4561	1104	790	4280	2200	164	16.00	6.10	63.00	2.21	22.82	22.20							