

### Physical and Aesthetic Parameters in Drinking Water of Khuzdar (Balochistan)

S.#	S.Code	Site ID	Location	Source	pH	EC	Turbidity	Colour	Taste	Odour
1	KHU-01	1	Dy. Commissioner Office	T.Well	7.80	960	23.00	-	Unobject	Less
2	KHU-02	2	Irrigation Colony	T.Well	7.70	1240	0.01	-	Unobject	Less
3	KHU-03	3	Park Near Public School	T.Well	7.50	1290	0.00	-	Unobject	Less
4	KHU-04	4	Civil Hospital Faqirabad	T.Well	7.30	1350	0.07	-	Unobject	Less
5	KHU-05	5	Madrisa Jamai-e-Rizvia Khalilia Khund	H.Pump	7.60	906	1.60	-	Unobject	Less
6	KHU-06	6	Filtration Plant Khuzdar Cantt.	W.Sply	8.10	945	1.40	-	Unobject	Less
7	KHU-07	7	Madrisa Tajweed-ul-Quran Katan	Well	7.30	1420	11.70	-	Unobject	Less
8	KHU-08	8	Pir Umar Mazar	Spring	7.70	953	19.30	-	Unobject	Less
9	KHU-09	9	Super Shashan Hotel Karachi Road (New Site)	Tap	7.70	947	1.20	-	Unobject	Less
10	KHU-10	10	Engineering University Khuzdar (New Site)	Cistern	7.70	964	24.40	-	Unobject	Less
11	KHU-11	11	Rahim Abad Near BRC College (New Site)	W.Sply	8.10	600	0.45	-	Unobject	Less

Minimum	7.30	600	0.00
Average	7.68	1052	7.56
Maximum	8.10	1420	24.40