

Physical and Aesthetic Parameters in Drinking Water of Loralai (Balochistan)

S.#	S.Code	Site ID	Location	Source	pH	EC	Turbidity	Colour	Taste	Odour
1	LOR-1	5	Army Water Purification Plant	W.Sply	7.60	562	0.03	-	Unobject	Less
2	LOR-2	2	Tubewell Commissioner Office	T.Well	7.50	780	0.39	-	Unobject	Less
3	LOR-3	2	Rodlin Village Quetta Road	Well	Dried					
4	LOR-4	4	Tank Quetta Road	W.Sply	7.60	817	0.06	-	Unobject	Less
5	LOR-5	7	P.H.E Pathan Kot	T.Well	7.40	798	0.03	-	Unobject	Less
6	LOR-6	6	Pathan Kot Springs	Spring	7.70	600	0.51	-	Unobject	Less
7	LOR-7	3	OHSR Baloch Colony	W.Sply	7.60	920	0.17	-	Unobject	Less
8	LOR-8	1	Zangiwal Near Oregi River	T.Well	Dried					
9	LOR-9	1	Torkhezai Delay Action Dam	Dam	7.7	250	400	Muddy	Object.able	Less
10	LOR-10	4	T&T Centre Near Awami Centre	Well	7.20	1740	16.80	-	Unobject	Less
11	LOR-11	1	Zangi Village	Well	7.40	930	0.12	-	Unobject	Less
12	LOR-12	1	Torkhezai Road Zangiwal (New Site)	T.Well	7.50	700	0.06	-	Unobject	Less
13	LOR-13	4	Main Bazar Near Police Line (New Site)	Tap	7.70	820	0.25	-	Unobject	Less

Minimum 7.20 250 0.03
 Average 7.54 811 38.04

Maximum 7.70 1740 400.00

L